

# Certificate of Conformity

By the product certificate number

No. 2620/0019-A-E1-CER

Issued to

License holder: **Victron Energy B. V.**  
De Paal 35, 1351 JG Almere – Netherlands



Trademark:



Contract number: **801264**

It is certified that the product:

Type of generator: **Inverter / charger with UPS functionality.**  
- **AC (grid): 2 inputs and 2 outputs.**  
- **DC (batteries): 1 input and 1 output.**

Family: **Quattro**

Models:	48/15000/200-100/100	48/10000/140-100/100	48/8000/110-100/100
Technical Data:			
Rated AC Power	15 kVA / 12 kW	10 kVA / 8 kW	8 kVA / 6.5 kW
Rated AC Voltage	230 Vac	230 Vac	230 Vac
Rated AC Frequency	50 Hz	50 Hz	50 Hz
DC Current (IN / OUT)	200 A / 350 A	140 A / 235 A	100 A / 188 A
DC Voltage (IN / OUT)	48 Vdc	48 Vdc	48Vdc
Firmware version	2656475.1	2653475.1	2655475.1
Number of phases	Single Phase	Single Phase	Single Phase
Isolation transformer	Yes	Yes	Yes

Is in compliance with:

Regulation **IEC 62116:2014**  
Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters.

The above-mentioned generating unit is certified according to the SGS internal procedure PE.T-ECPE-18 based on the requirements of the UNE-EN ISO / IEC 17065

This certificate cancels and supersedes the certificate no. 2620/0019-A-CER/E1.

First issued on: 23<sup>rd</sup> of September 2020.

This certificate is valid until: 23<sup>rd</sup> of September 2023.

Madrid, 6<sup>th</sup> May 2021



Daniel Arranz Muñiz  
Certification Manager

